

## CHAPTER 161

# ELECTRICAL CODE

**161.01 ELECTRICAL CODE.** The City of Iowa Falls requires all electrical licensing, permitting and inspections to comply with Iowa Code Section 103 Electricians and Electrical Contractors. The following additions are hereby made: 1) There shall be an electrical disconnect installed by the electrical meter on all new electrical services outside of the structure with a fused or breaker disconnect. Two ground rods 8 feet apart are required. 2) Copper wire shall be used from utility service at weather head to the inside building breaker panel.

*(Ch. 161 – Ord. 1058 – Oct. 14 Supp.)*